

Title	Report 235: Guidelines on the use of water mist fire extinguishment systems in E&P industry applications
Publisher/Author	OGP
Publication Date	1996
Scope	This is the third in a series of special topic reports supplementing "Guidance on halon free fire protection" (6.39/214). In some instances, conventional water deluge sprinklers are effective fire protection systems. However, emerging technology in water mist systems has many potential applications replacing halon fixed flood systems. The report provides information to aid selection and design of water mist fire extinguishment systems, and summarises findings on their use in E&P applications, and discusses new applications that are under development.